

October 21, 2008

HYDRO INTERNATIONAL
JOHN MACKINNON
94 HUTCHINS DR
PORTLAND ME 04102

Re: Description: STORMWATER TREATMENT DEVICE
Manufacturer: HYDRO INTERNATIONAL
Product Name: DOWNSTREAM DEFENDER®
Model Number(s): 10-FT.
[HYDRODYNAMIC VORTEX SEPARATOR FOR STORMWATER TREATMENT; SIZED AT
MAX. FLOW RATE OF 11200 GPM/25.0 CFS; 12 IN. DIA. MAX. INLET/OUTLET PIPES;
FOR USE IN NEW AND RETROFIT APPLICATIONS]
Product File No: 20080562

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- Prior to installation of this product, plans and specifications must be submitted to the department or to an approved agent municipality for review and approval in accordance with s. Comm 82.20 (1) of the Wis. Admin. Code. Written approval for the plans and specifications shall be obtained prior to installation of the product.
- The review undertaken by Commerce staff does not include review and/or approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product is approved for the following uses, as specified in Table Comm 82.70-1:
 - Stormwater and clearwater subsurface detention system,
 - Stormwater and clearwater subsurface infiltration system, or
 - Stormwater and clearwater subsurface detention/infiltration system
- Installation-- Installation of this product must be in accordance with the manufacturer's printed installation instructions. A copy of the manufacturer's installation instructions must be given to the property owner, installer and submitted along with other information required by the governing agency for the installation.
- This product submittal has been reviewed and approved for plumbing treatment standards for subsurface infiltration and irrigation using stormwater as the source, as listed in Table Comm 82.70-1. **Each site-specific installation shall be submitted for review and include acceptable methods, modeling, or analysis to predict efficiency for TSS and oil & grease removal.**
- When this product is installed in other than a Hydro International manhole riser/catch basin, a department-approved precast concrete manhole riser meeting the design criteria for this product, as specified by Hydro International, is required.

October 21, 2008

- Labeling: This product shall be permanently labeled identifying the manufacturer and model number (Hydro International, Downstream Defender®, serial no. and US Patent No.). Labeling occurs on the heavy duty cover as an affixed metal plate; the manhole cover has recessed letter noting manufacturer's name.
- Inspection and maintenance of this product must be performed at intervals specified by the manufacturer (Downstream Defender®, ver. 1.0, 9/19/2008) or in accordance plan approval or s. Comm 82.21, whichever is more restrictive. During the first year of operation, inspections are to be scheduled every 6 months; thereafter, inspections to be scheduled on an annual basis or as determined by site-specific rate of pollutant contaminants.
- Any plumbing plans that include this device(s) and submitted to Commerce shall be accompanied by an acceptable modeling method, such as outlined in Method for Predicting the Efficiency of Proprietary Storm Water Sedimentation Devices (1006) for the specific site where the installation of this device(s) is planned. **The submitted calculations, based on site-specific inputs, shall predict the removal efficiencies by concentration and percentage. For particle size distribution, in SLAMM use file: NURP.cpz.**
For a copy of this standard, see:
http://dnr.wi.gov/runoff/pdf/stormwater/techstds/prop_devices_std_v2_051408.pdf
- Inspection and maintenance of this product must be performed at intervals specified by the manufacturer (Downstream Defender®, ver. 1.0, 9/19/2008) or in accordance plan approval or s. Comm 82.21, whichever is more restrictive. During the first year of operation, inspections are to be scheduled every 6 months; thereafter, inspections to be scheduled on an annual basis or as determined by site-specific rate of pollutant contaminants.
- Maximum storage capacity: total sediment storage—8.7 cubic yards; oil storage— 1050 gallons.

Maximum flow rates: peak treatment flow— 25.0 cfs; head loss— 10.0 inches.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov